

San Joaquin Valley Unified Air Pollution Control District

PERMIT UNIT: S-1394-57-1

EXPIRATION DATE: 4/30/2002

EQUIPMENT DESCRIPTION:

23,100 GALLON FIXED ROOF OIL STORAGE TANK # 774 WITH A TRUE VAPOR PRESSURE LESS THAN 1.5 PSIA - 16'5" DIAMETER X 14'8" HIGH

Permit Unit Requirements

1. True vapor pressure of the petroleum liquid stored shall be less than 1.5 psia. [District Rule 4623 and 40 CFR 60.112a(a)] Federally Enforceable Through Title V Permit
2. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
3. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in section 6.2 of District Rule 4623 and API Bulletin 2517 (Evaporation Loss from External Floating Roof Tanks). [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit